



Mild steel straps to hold
tile in place while ramming

Note: Raised corrugation to be installed
against working face of plastic refractory

Dim. 'A'	Anchor Req'd	
	B	C
17-9/16"	T13	T12
20-1/16"	T13	T13
22-5/16"	T14	T13
24-11/16"	T14	T14
27-1/16"	T15	T14
29-7/16"	T15	T15

Choose the closest anchor combination
and add 1/2" S.S. Bolt to reach
desired wall thickness

Ref: B-177-13

Plibrico Company
REFRACTORY ENGINEERING & CONSTRUCTION FOR
BOILERS . INCINERATORS . INDUSTRIAL FURNACES
CHICAGO, ILLINOIS RATIONWIDE SERVICE

**Ceramic Tile
Combinations**

DATE 9/92 No. 9

This drawing is the property of the
Plibrico Company and is loaned without
consideration other than the borrower's
agreement that it shall not be reproduced,
copied, loaned, or disposed of, directly or
indirectly, nor used for any purpose other
than that for which it is specifically
furnished.